



**IMST GmbH**

Carl-Friedrich-Gauß-Str. 2-4, D-47475 Kamp-Lintfort

# iOKE868 LoRaWAN®

## AN035 - Radio Protocol

Version 1.3

### **Document State**

initial

### **Date**

26.09.2024

### **Document ID**

4000/40140/0168

© 2024 IMST GmbH - All rights reserved

# History

Version	Date	Chapter	Description
1.0	22.01.2021	all	Initial Version
1.1	02.03.2023	Meter Data Message - Status Field	Updates with respect to firmware V1.2
1.2	19.03.2024	Status Message	New "Reserved Info Field" added to Status Message ( Firmware V1.3 ff)
1.3	26.09.2024	Application Messages and LoRaWAN® Ports	Port for Scanned OBIS-IDs Message added
		Scanned OBIS-IDs Message	Message format for scanned OBIS-IDs Message added

## Aim of this document

This document outlines the radio protocol including the application message formats which are supported by iOKE868 LoRaWAN.

### Notation Info

Suffix "b" = binary data

Suffix "h" = hexadecimal data

Without suffix = decimal data

Multi byte / octet fields are considered to be treated as unsigned integers with **Least Significant Byte** first unless explicitly noted

## Content

- Introduction
- LoRaWAN Protocol®
- Upload of Application Data
- Transport Protocol Details
- Application Messages and LoRaWAN® Ports
- Disclaimer



# Introduction

The iOKE868 LoRaWAN® includes an optical meter readout unit iO881A which is able to transmit sampled meter data to a LoRaWAN® network.

The following chapters explain the implemented Application Protocol and Tiny Transport Protocol which is used above the LoRaWAN® Protocol.




Figure : Radio Protocol Stack

# LoRaWAN Protocol®

## Activation

The LoRaWAN Protocol® offers two types of activation which need to be performed before any application data exchange with a network server can be started. Both versions OTAA (Over The Air Activation) and ABP (Activation by Personalization) are supported and can be configured with the required parameters.

## Time Synchronization

The implemented LoRaWAN® Stack is compliant to LoRaWAN version 1.0.2 and extends the defined functionality with some features of version 1.0.3. One feature is the network time synchronization which is implemented by means of a specific LoRaWAN MAC command. Network time synchronization is done automatically after activation and every device restart. Due to the fact that LoRaWAN server based on protocol version 1.0.2 do not support the newer LoRaWAN MAC command a fallback mechanism is supported by means of an proprietary application command. The current time synchronization state is signaled in the iO881A system status which can be uploaded to the network server.


## Confirmed Data Upload

Uploading of any application data uses the confirmed data exchange service i.e. a single radio packet have to be acknowledged from a LoRaWAN network server before a next packet can be sent.

# Upload of Application Data

The reliable upload of application data like captured meter data or firmware status is implemented by means of confirmed LoRaWAN® uplink packets and a simple segmentation protocol with minimal overhead of one single byte. In case of insufficient LoRaWAN® payload capacity the meter readout results will be transmitted by means of multiple LoRaWAN® packets. Note: Application data which will fit into a single LoRaWAN packet is transmitted without the transport protocol header. The given LoRaWAN Port indicates if the current LoRaWAN packet contains segmented or unsegmented data.

Application data which fits into a single LoRaWAN packet



Application data spreaded over several LoRaWAN packets ( in case of huge payload and large spreading factors )




Figure : Unsegmented and segmented application data upload

# Transport Protocol Details

The transport protocol is used in uplink- and downlink direction on several LoRaWAN® ports which indicate the type of message content. The protocol uses a single octet header field with following format:

TP Header	
Bit 7	Bit 6 ... Bit 0
Last Segment	Segment Number 0 .. 127

Figure : Transport Protocol Header

- Last Segment Indicator (Bit 7)  
This bit indicates the last segment of a transmission if set to "1".
- Segment Number (Bit 0 .. 6)  
The segment number starts at zero for every new transmission and will be incremented by "1" for every new segment. On receiver side it might happen that duplicated segment numbers will appear. In this case the receiver should simply ignore the duplicate segments. The segment number can wrap around from 127 to 0 in case of very large transmissions and tiny segments.

The following figure outlines a transmission consisting of four different segments and one re-transmitted segment.




Figure : Example transmission sequence with four segments and one retransmission

## Application Messages and LoRaWAN® Ports

The LoRaWAN® Protocol supports port numbers which are used within this application to identify different kind of messages.

Please note that the same application message type can be transmitted either unsegmented or segmented, depending on the current LoRaWAN payload capacity, which may change due to radio link conditions.

The following ports are used for unsegmented messages:

LoRaWAN® Port	Message Type
03 <sub>h</sub>	Status Message
05 <sub>h</sub>	Meter Data Message
08 <sub>h</sub>	Scanned OBIS-IDs Message
32 <sub>h</sub>	Time Synchronization

The following ports are used for segmented messages:

LoRaWAN® Port	Message Type
43 <sub>h</sub>	Status Message
45 <sub>h</sub>	Meter Data Message
48 <sub>h</sub>	Scanned OBIS-IDs Message

### Implemented Application Messages

- Status Message
- Meter Data Message
- Time Synchronization Message
- Scanned OBIS-IDs Message

## Status Message

The iO881A maintains some status information elements which can be transmitted over LoRaWAN® or requested via local serial interface. The transmission can be initiated by means of a calendar event.

Status Message									
System Time	Firmware Version		Last Sync	Status		Meter Data Packet Counter			Firmware V1.3 ff
UTC Format LSB first	Minor Version	Major Version	UTC Format LSB first	Reset Counter LSB first	Status Bits	Correct received Meter Files LSB first	Incorrect received Meter Files LSB first	Uploaded Meter Data Messages LSB first	Reserved Info
32 Bit	8 Bit	8 Bit	32 Bit	32 Bit	16 Bit	32 Bit	32 Bit	32 Bit	8 Bit

Figure : iO881A Status Message Format

The iO881A Status Message consists of the following elements:

- iO881A System Time ( from embedded RTC )
- Firmware Version
- Time of last Synchronization
- Reset Counter
- Status / Error Bits
  - Bit 0: LoRaWAN® Activation State
    - 1 = LoRaWAN® Stack is not activated
    - 0 = Stack is activated
  - Bit 1: Network Time Synchronization State
    - 1 = No synchronization via LoRaWAN®
    - 0 = Synchronized via LoRaWAN®
  - Bit 2: System Time Synchronization State
    - 1 = RTC not synchronized at all
    - 0 = RTC synchronized ( via local serial interface or LoRaWAN® )
  - Bit 3: Over The Air Activation Procedure State
    - 1 = OTAA procedure active
    - 0 = OTAA procedure not active
  - Bit 4: LoRaWAN Configuration State
    - 1 = Configuration is invalid Activation not possible
    - 0 = Configuration is valid
  - Bit 5: Reserved
  - Bit 6: Calendar Event List Configuration State
    - 1 = List is empty in this case a default "Get Network Time" event is scheduled every hour at 05:00min for RTC synchronization
    - 0 = List contains at least one item
  - Bit 7: OBIS ID Filter List Configuration State
    - 1 = List is empty
    - 0 = List contains at least one filter item
- Reader Counters
  - Number of correctly received meter files
  - Number of faulty received meter files with read / CRC errors
  - Number of uploaded meter data messages

Note: These counters can be reseted via local serial interface



## Meter Data Message

The following figure outlines the Meter Data Message format in more detail:

Note: The presence of optional fields like Status Field, Time Field or Meter ID Field is configurable!

Figure : Meter Data Message Format

### Format Description of Message Fields

- Meter Data Message - General Message Field Format
- Meter Data Message - Status Field
- Meter Data Message - Time Field
- Meter Data Message - Meter ID Field
- Meter Data Message - Meter Object Field with Number and Unit
- Meter Data Message - Meter Object Field with Number only ( no Unit )
- Meter Data Message - Meter Object Field with String
- Meter Data Message - OBIS-ID Field

## Meter Data Message - General Message Field Format

All defined message fields have the following common format:

General Message Field Format		
Type Field	Length Field	Data Field
1 Byte	1 Byte	1 - 57 Bytes

Figure: General Message Field Format

Every Message Field consist of three sub fields: Type Field, Length Field and Data Field

### **Type Field**

The Type Field defines the type of data which is included in the data field.

Type	Message Field
00h	Status Field
01h	Time Field
10h	Meter ID Field
40h	Meter Object with Number and Unit
41h	Meter Object with Number ( no Unit )
42h	Meter Object with String

### **Length Field**

The Length Field indicates the number of bytes which are present in the data field.

### **Data Field**

The Data Field contains the specific data.

## Meter Data Message - Status Field

The Meter Status Field is an optional field which includes some status information about the incoming meter data stream

Status Field			
Type Field 00 <sub>h</sub>	Length Field 02 <sub>h</sub>	Data Field	
		Info Field	Error / Status
1 Byte	1 Byte	1 Byte	1 Byte

Figure: Status Field Format

### **Info Field ( Firmware 1.2 ff)**

This sub field includes some information about the kind of meter data input:

Bits 7 .. 5 : reserved

Bits 4 .. 2 : Protocol Type

- 0 = unknown
- 1 = IEC Mode A
- 2 = IEC Mode B
- 3 = IEC Mode C
- 4 = IEC Mode D
- 5 = Reserved
- 6 = SML

Bits 1 .. 0: Meter Type

- 0 = unknown
- 1 = Import Meter ( Consumption )
- 2 = Export Meter ( Production )
- 3 = Import and Export Meter

### ***Info Field ( Firmware 1.0 - 1.1 )***

This sub field includes some information about the kind of meter data input:

Bits 7 .. 4 : reserved

Bits 3 .. 2 : Protocol Type

- 0 = unknown
- 1 = SML
- 2 = IEC
- 3 = reserved

Bits 1 .. 0: Meter Type

- 0 = unknown
- 1 = Import Meter ( Consumption )
- 2 = Export Meter ( Production )
- 3 = Import and Export Meter

### ***Error / Status Field***

This sub field contains an error code:

- 0 = ok, no error
- 1 = no input data
- 2 = read error / CRC error occurred while reading input data
- 3 = input file seems to be incomplete
- 4 = pairing error, incoming meter ID doesn't match with paired one
- 5 = no filtered data

### **Meter Data Message - Time Field**

The Meter Time Field is an optional field which includes a 32-Bit timestamp derived from the reader internal RTC when an incoming meter file gets parsed.

The time stamp is encoded with MSB first byte ordering !

Time Field		
Type Field 01 <sub>h</sub>	Length Field 04 <sub>h</sub>	32 Bit Time Stamp ( UTC format, MSB first)
1 Byte	1 Byte	4 Byte

Figure: Time Field Format

## Meter Data Message - Meter ID Field

The Meter ID Field is an optional field which includes the Meter ID of the connected Smart Meter.

Meter ID Field		
Type Field 10 <sub>h</sub>	Length Field 1 - max. 16	Meter ID String
1 Byte	1 Byte	1 - max. 16 Bytes

Figure : Meter ID Field Format

## Meter Data Message - Meter Object Field with Number and Unit

This Field includes a meter data record which consists of an OBIS-ID Field, a Unit Field, a Scaler Field and the final Mantissa Field:

Meter Object Field with Number and Unit						
Type Field 40 <sub>h</sub>	Length Field 5 - max. 57	OBIS-ID Field		Unit Field	Scaler Field ( signed Integer)	Mantissa Field
		Group Mask	OBIS-ID Value			
1 Byte	1 Byte	1 Byte	1 - max. 6 Bytes	1 Byte	1 Byte	1 - typ. 8 Bytes, max. 48 Bytes, MSB first

Figure : Meter Object Field with Number and Unit

## Meter Data Message - Meter Object Field with Number only ( no Unit )

This message field format is an alternativ to the previous one. In cases where keeping the radio payload as short as possible is more import than the knowledge of the unit, one can configure the usage of this message field format.

This field includes a meter data record which consists of an OBIS-ID Field, a Scaler Field and the final Mantissa Field. The Unit field is simply omitted.

Meter Object Field with Number only ( no Unit )					
Type Field 41 <sub>h</sub>	Length Field 4 - max. 56	OBIS-ID Field		Scaler Field ( signed Integer)	Mantissa Field
		Group Mask	OBIS-ID Value		
1 Byte	1 Byte	1 Byte	1 - max. 6 Bytes	1 Byte	1 - typ. 8 Bytes, max. 48 Bytes, MSB first

Figure : Meter Object Field with Number only ( no Unit )

## Meter Data Message - Meter Object Field with String

This message field format is used in cases where the meter data record contains a string and not a number with scaler (exponent) and mantissa.

Meter Object Field with String				
Type Field 42 <sub>h</sub>	Length Field 3 - max. 55	OBIS-ID Field		String
		Group Mask	OBIS-ID Value	
1 Byte	1 Byte	1 Byte	1 - max. 6 Bytes	1 - max. 48 Bytes

Figure : Meter Object Field with String

## Meter Data Message - OBIS-ID Field

The OBIS ID Field which is used in several meter data messages consists of the following subfields:

OBIS-ID Field	
Group Mask	OBIS-ID Value
1 Byte	1 - max. 6 Bytes

Figure : OBIS-ID Field

The Group Mask indicates which of the six possible OBIS-ID Group values A-F is included in the following OBIS-ID Value Field.

The Bit-Mapping is as follows:

- Bit 7 = 1 OBIS-ID Group A attached
- Bit 6 = 1 OBIS-ID Group B attached
- Bit 5 = 1 OBIS-ID Group C attached
- Bit 4 = 1 OBIS-ID Group D attached
- Bit 3 = 1 OBIS-ID Group E attached
- Bit 2 = 1 OBIS-ID Group F attached
- Bit 1 : used
- Bit 0 : not used

The OBIS ID Value Field includes up to six octets which contain the corresponding OBIS-ID Group values.

### Example 1

GroupMask =  $11111100_b = FC_h$  ( all 6 OBIS ID values attached )

OBIS-ID Value = 01 00 01 08 00 FF "1-0:1.8.0\*255"

### Example 2

GroupMask =  $00111000_b = 38_h$  ( OBIS ID Groups C, D, E attached )

OBIS-ID Value = 01 08 00 "?-?:1.8.0\*?"

## Time Synchronization Message

The following figure outlines the Time Synchronization Message format which is used in case the LoRaWAN server does not support a corresponding LoRaWAN MAC Layer service.

This message type follows a generic format which is also used for other purposes. The uplink request message looks as follows:

Get Date Time Request	
Request Type "Get" ( 01 <sub>h</sub> )	Resource ID "DateTime" ( 01 <sub>h</sub> )
1 Byte	1 Byte

Figure : Get Date Time Request Message Format

The expected server downlink response must be transmitted to the same LoRaWAN Port 32<sub>h</sub> and should include the current date and time as seconds since epoch (UTC) .

Get Date Time Response		
Request Type "Get Response" ( 02 <sub>h</sub> )	Resource ID "DateTime" ( 01 <sub>h</sub> )	Seconds since epoch (UTC) unsigned 32-Bit integer, LSB first ( e.g. 19 9E 64 5F <sub>h</sub> )
1 Byte	1 Byte	4 Byte

Figure : Get Date Time Response Message Format

Timestamp conversion can be easily verified online ( see <https://www.epochconverter.com/> ).

In this example: 19 9E 64 5F<sub>h</sub> => swap LSB first to MSB first => 5F649E19<sub>h</sub> => convert from hex to decimal => 1600429593 => copy to web site => results to

GMT: Friday, 18. September 2020 11:46:33

Your time zone: Freitag, 18. September 2020 13:46:33 GMT+02:00 DST



### Scanned OBIS-IDs Message

The following figure outlines the message format in more detail:

Scanned OBIS-IDs Message				
OBIS-ID Field #1		...	OBIS-ID Field #n	
Group Mask	OBIS-ID Value		Group Mask	OBIS-ID Value
1 Byte	1 - max. 6 Bytes	...	1 Byte	1 - max. 6 Bytes

Figure : Scanned OBIS-IDs Message

The detailed format for OBIS-ID Field can be found here: [Meter Data Message - OBIS-ID Field](#)



# Disclaimer

IMST GmbH points out that all information in this document are given on an “as is” basis. No guarantee, neither explicit nor implicit is given for the correctness at the time of publication.

IMST GmbH reserves all rights to make corrections, modifications, enhancements, and other changes to its products and services at any time and to discontinue any product or service without prior notice. It is recommended for customers to refer to the latest relevant information before placing orders and to verify that such information is current and complete. All products are sold and delivered subject to “General Terms and Conditions” of IMST GmbH, supplied at the time of order acknowledgment.

IMST GmbH assumes no liability for the use of its products and does not grant any licenses for its patent rights or for any other of its intellectual property rights or third-party rights. It is the customer's duty to bear responsibility for compliance of systems or units in which products from IMST GmbH are integrated with applicable legal regulations. Customers should provide adequate design and operating safeguards to minimize the risks associated with customer products and applications.

The product is not approved for use in life supporting systems or other systems whose malfunction could result in personal injury to the user. Customers using the product within such applications do so at their own risk.

Any resale of IMST GmbH products or services with statements different from or beyond the parameters stated by IMST GmbH for that product/solution or service is not allowed and voids all express and any implied warranties. The limitations on liability in favor of IMST GmbH shall also affect its employees, executive personnel and bodies in the same way. IMST GmbH is not responsible or liable for any such wrong statements.